

Er. VAIBHAV GARG

BE, C. Engn, MIE, FIV

990, Khero Bazar, JAGADHRI-135 003

☎: 01732-297508 (O), M. : 94160-29508

email : bnbvaibhav@gmail.com

Chartered Engineer & Registered Valuer

Date: 15-03-2024

Ref No: 2324/03-02

To Whomsoever It May Concern

SAFETY CERTIFICATE OF THE SCHOOL BUILDING


I, Er Vaibhav Garg, Regd Valuer & Engineer has inspected the following school building on March 15, 2024.

Name of the school: Shivalik Senior Secondary School, Sabapur, Distt Yamuna Nagar.

Dr Sohan Lal, Principal of the school was also present in the school at the time of inspection. The school is run by Krishna Educational Society, VPO Sabapur, tehsil Bilaspur, Distt Yamuna Nagar.

The school building was constructed in the years 2013-14. This is a double storied school. The structural elements are in healthy condition and do not pose any threat to human life. Various provisions of different IS codes (related to construction and various loads like seismic, wind) seem to have been incorporated for the construction of this school building.

It is hereby certified that the school buildings are structurally safe.



Name: Er VAIBHAV GARG
Qualifications: BE (Civil), C Engn, MIE, FIV.
Registration No: M/131435/6

The Principal
Shivalik SR SEC School
Sebabapur, District Yamuna Nagar

666
21-03-24

Memo no

Dated

Sub.: **Reagarding issues of Building safety certificate of Shivalik Sr. Sec. School Sabapur Distt. Yamuna Nagar.**
Ref. **Your letter No.555/03/24/05 dated 13.03.2024.**

In this connection, it is intimated that the building of **Shivalik Sr. Sec. School Sabapur, Yamunanagar** has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.1 PWD B&R Br Yamunanagar alongwith concerned J.E. and has reported that upon visual (physical inspection, the building apparently seems to be safe as there is no crack/settlement observed. As the building cited under subject has not been constructed under the supervision of PWD B&R Branch, as far as seismic factor and structural safety of the building is concerned, advice of the **Structural consultant** may be sought. The certificate is valid for one year only.

This is for your kind information and further necessary action please.

DA/II

sd-
Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.
Yamuna Nagar

Endst No. 9553

Dated:- 21-03-24

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.1, PWD B&R Br., Yamunanagar for information. This is with reference to his office letter No.591 dated 18.03.2024.

DA/II

Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br
Yamuna Nagar

only for information
may file

SSEPR